



NOTES:

VALVE SHALL NOT BE LESS THAN 12" OR MORE THAN 18" BELOW GRADE.

LID SHALL BE:

1. LAWN AND SIDEWALK AREAS – PRECAST CONCRETE, CHRISTY F8D OR APPROVED EQUAL.
2. STREET AND PARKING LOTS – CAST IRON TRAFFIC LID, CHRISTY F8C OR APPROVED EQUAL.



CITY OF DALY CITY, CALIFORNIA
DEPARTMENT OF PUBLIC WORKS

GATE VALVE ASSEMBLY

REVIEWED BY: *Richard Chen*
CITY ENGINEER

ADOPTED ON: DEC 10, 2018
CITY COUNCIL

STANDARD
DETAIL

PR-8

DATE: NOV 2018