



NOTES:

1. BACKFLOW UNITS SHALL BE ON THE "APPROVED BACKFLOW PREVENTION DEVICES" LIST BY THE HEALTH SERVICES AGENCY, A DEPARTMENT OF THE PUBLIC HEALTH AND ENVIRONMENTAL PROTECTION DIVISION OF THE COUNTY OF SAN MATEO. SEE SECTION 02710-10 PARAGRAPH 2.04 E, FOR REDUCED PRESSURE BACKFLOW PREVENTION DEVICE
2. UNIT SHALL BE TESTED AND CERTIFIED BY COUNTY REGISTERED TESTER.
3. DETAILS SHOWN ON THIS PLAN ARE FOR LANDSCAPE IRRIGATION SYSTEMS ONLY. FOR DETAILS OF FIRE AND OTHER BACKFLOW PREVENTION DEVICES, SEE PROJECT PLANS AND SPECIAL PROVISIONS.
4. DEVICES 2" AND SMALLER SHALL INCORPORATE BALL VALVES INSTEAD OF OS & Y VALVES.
5. BFP ENCLOSURE IS REQUIRED AND SHALL BE SUBMITTED FOR APPROVAL.



CITY OF DALY CITY, CALIFORNIA
DEPARTMENT OF PUBLIC WORKS

STANDARD
DETAIL

REDUCED PRESSURE BACKFLOW PREVENTION DEVICE

W-10

REVIEWED BY: *Richard Chou*
CITY ENGINEER

ADOPTED ON: DEC 10, 2018
CITY COUNCIL

DATE: NOV 2018