



SCHEMATIC PLAN
NOT TO SCALE

NOTE:

1. EACH VALVE OUTSIDE OF METER BOX SHALL HAVE A VALVE BOX.
2. WATER METER REGISTER SHALL BE TOUCH-READ TYPE. REGISTER COVER SHALL BE NO MORE THAN 11" BELOW TOP OF COVER. READING LID DOES NOT HAVE TO BE CENTERED OVER REGISTER.
3. INSTALLATION DRAWINGS MUST BE APPROVED BY DEPARTMENT OF WATER/WASTEWATER RESOURCES.
4. CITY FURNISHES METER WITH STRAINER AFTER PAYMENT TO THE CITY. CONTRACTOR SETS METER/STRAINER AND METER BOX.
5. SEE SECTION 02710 FOR EQUIPMENT OPTIONS.



CITY OF DALY CITY, CALIFORNIA
DEPARTMENT OF PUBLIC WORKS

WATER SERVICE LATERAL - 2" & LARGER

REVIEWED BY: *Richard Chow Jr.*
CITY ENGINEER

ADOPTED ON: DEC 10, 2018
CITY COUNCIL

STANDARD
DETAIL

W-3

DATE: NOV 2018