



NOTES:

1. AIR RELEASE VALVE SHALL BE LOCATED IN LAWN OR SIDEWALK AREAS AS FIRST CHOICE
2. USE COPPER PIPE INSTEAD OF BRASS PIPE, IF THE WATER MAIN IS PLACED IN THE STREET



CITY OF DALY CITY, CALIFORNIA
DEPARTMENT OF PUBLIC WORKS

STANDARD
DETAIL

AIR RELEASE VALVE ASSEMBLY

W-9

REVIEWED BY: *Richard Chao*
CITY ENGINEER

ADOPTED ON: DEC 10, 2018
CITY COUNCIL

DATE: NOV 2018