



NOTES:

VALVE SHALL NOT BE LESS THAN 12" OR MORE THAN 18" BELOW GRADE.

LID ARE AS FOLLOWS:

1. LAWN AND SIDEWALK AREAS ..... PRECAST CONCRETE, CHRISTY F8D OR EQUAL.
2. STREET AND PARKING LOTS ..... CAST IRON TRAFFIC LID, CHRISTY F8C OR EQUAL.

CITY OF DALY CITY, CALIFORNIA

DEPARTMENT OF PUBLIC WORKS

DRAWN BY : A. TAN

GATE VALVE ASSEMBLY

DATE: 6/03

APPROVED BY: MP Sharma, CITY ENGINEER

STANDARD DRAWING NO. PR-10

Project: 1417  
 City: Daly City, California  
 Date: 7/7/1997

Time: 13:30:54  
Date: 7/7/1997