



SECTION
ONE - WAY CLEAN OUT DETAIL

NOTES:

1. BACKWATER VALVE IS REQUIRED WHEN SLOPE OF SEWER LATERAL FROM BUILDING TO SEWER MAIN IS LESS THAN 2% OR WHEN THE LOWEST FIXTURE IN THE BUILDING IS BELOW THE RIM OF THE NEXT DOWNSTREAM MANHOLE.
2. CLEANOUT AND BUILDING SEWER PIPE SHALL BE PE SCHEDULE 11 OR 17 OR PVC SDR 26 OR 35.
3. SEWER RUNS OF 50 FEET OR LONGER MAY, AT THE OPTION OF THE ENGINEER/DWWR, REQUIRE AN ADDITIONAL CLEANOUT.