



NOTES:

1. WHERE DUCTILE IRON PIPE IS PROVIDED, IT SHALL BE CEMENT MORTAR LINED (CML). PIPE WITH MECHANICAL OR PUSH-ON JOINTS AS SPECIFIED FOR WATER MAIN UNDER CITY STD SPECIFICATION SECTION 02710.
2. BANDED RUBBER COUPLINGS OR EQUIVALENT FOR CLAY PIPE LATERALS SHALL BE USED IN COMBINATION WITH ELASTOMERIC TRANSITIONAL BUSHINGS