



ISOMETRIC DIAGRAM

NOTES:

1. ANY OF THE THREE TYPES OF CONNECTION SHOWN MAY BE USED, DEPENDING UPON FIELD REQUIREMENTS.
2. FOR BOTH 1-1/2" AND 2" METERS, ALL PIPING SHALL BE 2" IN DIAMETER.
3. SEE SECTION 02710 FOR EQUIPMENT OPTIONS.

MATERIAL REQUIREMENTS

A	SADDLE SERVICE MUELLER BR2B WITH AWWA FIPT
B	CORPORATION STOP MUELLER B-25028
C	ELL 2" BRONZE MIPT X FIPT
D	ELL 2" C TO I.P.T. MALE (ALT-MUELLER H15531)
E	TUBING 2" COPPER, SOFT K OR RIGID COPPER.
F	COUPLING 2" C TO C MUELLER H-15403
G	ADAPTOR, 2", MIPT x COPPER TUBING OR MUELLER H-15429
H	COPPER METER YOKE BY MUELLER: 1-1/2" METER = #B-2423-2-99000 2" METER = #B-2423-2-99000
I	METER BOX, CHRISTY FL36. SUPPLIED BY CITY AND SET BY CONTRACTOR
J	METER, 1-1/2" OR 2", SUPPLIED BY CITY AND SET BY CONTRACTOR.
K	CORPORATION STOP MUELLER B-20046

CITY OF DALY CITY, CALIFORNIA

DEPARTMENT OF PUBLIC WORKS

DRAWN BY : A. TAN

2" WATER SERVICE LATERAL FOR  
1-1/2" OR 2" METER

DATE: 6/03

APPROVED BY: MP Sharma

, CITY ENGINEER STANDARD DRAWING NO. W-3