



SCHEMATIC PLAN
NOT TO SCALE

NOTE:

1. EACH VALVE OUTSIDE OF METER BOX SHALL HAVE A VALVE BOX.
2. WATER METER REGISTER SHALL BE TOUCH-READ TYPE. REGISTER COVER SHALL BE NO MORE THAN 11" BELOW TOP OF COVER. READING LID DOES NOT HAVE TO BE CENTERED OVER REGISTER.
3. INSTALLATION DRAWINGS MUST BE APPROVED BY DEPARTMENT OF WATER/WASTEWATER RESOURCES.
4. CITY FURNISHES METER WITH STRAINER. CONTRACTOR SETS METER/STRAINER AND METER BOX.
5. SEE SECTION 02710 FOR EQUIPMENT OPTIONS.

CITY OF DALY CITY, CALIFORNIA

DEPARTMENT OF PUBLIC WORKS

DRAWN BY : I. SINGH

WATER SERVICE LATERAL - 3" & LARGER

DATE: 05/08

APPROVED BY: 

ACTING CITY ENGINEER

STANDARD DRAWING NO. W-4