



NOTES:

1. BACKFLOW UNITS SHALL BE ON THE "APPROVED BACKFLOW PREVENTION DEVICES" LIST BY THE HEALTH SERVICES AGENCY, A DEPARTMENT OF THE PUBLIC HEALTH AND ENVIRONMENTAL PROTECTION DIVISION OF THE COUNTY OF SAN MATEO. SEE SECTION 02710-10 PARAGRAPH 2.04 E, FOR REDUCED PRESSURE BACKFLOW PREVENTION DEVICE
2. UNIT SHALL BE TESTED AND CERTIFIED BY COUNTY REGISTERED TESTER.
3. DETAILS SHOWN ON THIS PLAN ARE FOR LANDSCAPE IRRIGATION SYSTEMS ONLY. FOR DETAILS OF FIRE AND OTHER BACKFLOW PREVENTION DEVICES, SEE PROJECT PLANS AND SPECIAL PROVISIONS.
4. DEVICES 2" AND SMALLER SHALL INCORPORATE BALL VALVES INSTEAD OF OS & Y VALVES.

CITY OF DALY CITY, CALIFORNIA

DEPARTMENT OF PUBLIC WORKS

DRAWN BY : A. TAN

REDUCED PRESSURE
BACKFLOW PREVENTION DEVICE

DATE: 07/07

APPROVED BY: MP Sharma, CITY ENGINEER

STANDARD DRAWING NO. W-8A