



PLAN

**NOTES:**

1. THE 3/4" METER WILL BE FURNISHED BY CITY UPON PAYMENT OF APPLICABLE FEES AT THE CITY'S CASHIER'S OFFICE.
2. CONTRACTOR SHALL FURNISH 3/4" COPPER OR BRASS / BRONZE TRIM WITH CURB STOP AND BACKFLOW DEVICE. BOTTOM OF LID TO TOP OF METER SHALL BE 6 INCHES.
3. CONTRACTOR SHALL PROVIDE THRUST BLOCKS IN CONFORMANCE WITH STD DWG W-10.
4. THE BACKFLOW DEVICE SHALL BE INSTALLED IN FRONT OF THE BUILDING OR IN LANDSCAPE AREA OR INSIDE THE BUILDING, IF SPACE IS LIMITED IN FRONT OF THE BUILDING.
5. USE WILKINS 375DA OR 475DA OR EQUIVALENT REDUCED PRESSURE DETECTOR ASSEMBLIES. A BACKFLOW SETLER, MODELS MJS, FFS AND MJFS, SHALL BE INSTALLED WITH THIS BACKFLOW DEVICE.

CITY OF DALY CITY, CALIFORNIA

DEPARTMENT OF PUBLIC WORKS

DRAWN BY : I. SINGH FIRE DETECTOR - CHECK VALVE AND CONNECTIONS

DATE: 07/07

APPROVED BY: MP Sharma, CITY ENGINEER STANDARD DRAWING NO. W-9