



PLAN

NOTES:

1. SIZE OF BOX / VAULT SHALL BE APPROVED BY CITY WITH APPROPRIATE EXTENSIONS, ALL AS PROVIDED BY CONTRACTOR. THE LID SHALL HAVE 1-3/4" DIA, HOLE DIRECTLY ABOVE THE METER FOR THE T - READ HOUSING.
2. CONTRACTOR SHALL CENTER THE METER READING LID OVER THE METER.
3. BOTTOM OF LID TO TOP OF METER SHALL BE 6 INCHES.
4. CONTRACTOR SHALL PROVIDE THRUST BLOCKS IN CONFORMANCE WITH STD DWG W-10.

CITY OF DALY CITY, CALIFORNIA

DEPARTMENT OF PUBLIC WORKS

DRAWN BY : acasilla

FIRE SERVICE FOR MULTI - STOREY RESIDENTIAL BUILDING
(AS REQUIRED)

DATE: 07/07

APPROVED BY: MP Sharma, CITY ENGINEER

STANDARD DRAWING NO. W-9A