



Guardrails



The porch and/or deck is constructed 30 inches or more above the ground and does not have a guard rail. Provide a guardrail around the perimeter of the porch and/or deck, no less than 42 inches above the floor of the porch and/or deck. [25 CCR 1502; Reference: California Residential Code R312]

