



# Park Electrical System



The electrical distribution panels, overcurrent devices, fuses or switches which serve the space, fixture, device or other equipment controlled at the distribution panels are not clearly and permanently marked. Clearly and permanently mark electrical distribution panels, overcurrent device, fuses or switches to identify the space, fixture, device or other equipment controlled at each distribution panel. [25 CCR 1134(a), 1151; Reference: California Electrical Code, Article 110-22, 230-70]