




# Sewer Connection




Incorrect

There is a plumbing hazard on the park lot. Sewer connection is not minimum approved schedule 40 pipe. Make the necessary repairs to eliminate the plumbing hazard. [25 CCR 1102(a)]



Correct



Incorrect

The drain line system is not maintained with a proper grade. A grade of not less than 1/8 inch per foot between the mobilehome or recreational vehicle and the lot drain inlet must be provided. [25 CCR 1358(d), 1606(e), 1607(e)]