



Stairway Landings



Incorrect



Correct

The stairway and/or landing is structurally unsound. Floor of the exterior landing shall not be more than 1 inch lower than the bottom of the outswing door. Replace or reconstruct the stairway and/or landing. [25 CCR 1498(a)(b), 1608(b)]